

## Pump Test Certification Form

For private wells without a valid well log.

Grant County Health District (GCHD) conducts water availability reviews for all building permit applications proposing a new structure which will have plumbing for potable water per Grant County Board of Health Resolution 99-2. In the event a valid well log is not available for submittal, a pump test may be required. Please indicate which pump test procedure was used.

☐ Pump Test Procedure 1

1. Be performed by an individual knowledgeable in well production testing.
2. Report static water level.
3. Report depth to water vs. time during pump down.
4. A sustained yield with stable water level for a minimum of four hours in excess of .37 gpm.
5. A depth to water vs. time for 90% of recovery to static level.
6. Include with this form all data collected during the pump test.

☐ Pump Test Procedure 2

1. Be performed by an individual knowledgeable in well production testing.
2. Report static water level.
3. Report depth to water vs. time during pump down.
4. If the well shows less than five feet of drawdown after pumping for one hour at five gallons per minute or more, this can be reported as a valid pump test.
5. Include with this form all data collected during the pump test.

Property Owner:	
Site Address:	
Parcel Number:	
Water Source: <input type="checkbox"/> Drilled Well <input type="checkbox"/> Dug Well	Well Tag ID:
Pump Test Completed By: (Please print) _____ Company: _____	
Date of pump test:	
I certify that this water source was pump tested in accordance with one of the above procedures. The actual pump test rate was _____ gallons per minute.	
_____ Signature of qualified individual	_____ Date